

**NOTICE OF ADDENDUM #1**  
**INVITATION TO BID #2019/20-06**  
**EVENTS CENTER PARKING LOT**

**This one (1) page must be completed and submitted with  
all other documents in the Bid.**

By signing this page and submitting a proposal, vendor hereby acknowledges that it/they have read and understand all terms, conditions, and requirements set forth in the ITB and the attached addendum #1. In addition, acknowledges the addenda(s) that have been issued.

**Vendor Information:**

Signature: \_\_\_\_\_

Print Name & Title: \_\_\_\_\_

Firm Name: \_\_\_\_\_

Mailing Address: \_\_\_\_\_

City, State, Zip: \_\_\_\_\_

Phone & Fax: \_\_\_\_\_

Email Address: \_\_\_\_\_

# NOTICE OF ADDENDUM #1

## INVITATION TO BID #2019/20-06

### EVENTS CENTER PARKING LOT

Issue Date: November 27, 2019

The Board of County Commissioners of Curry County, State of New Mexico, has issued the following Addendum #1 to the Invitation to Bid for Events Center Parking Lot, ITB No. 2019/20-06. Questions were invited and received and a compilation of questions were made and the following answers are provided.

#### Questions and Answers:

1. Question: "We use the NMDOT approved Crafcoc crack sealant. Will this product be satisfactory for crack sealing?"

Answer: Curry County will accept the NMDOT approved Crafcoc crack sealant.

2. Question: "We do not seal cracks less than 1/4" in width because the crack will not accept the material. Will this be satisfactory?"

Answer: Bidders shall apply crack sealer based on the manufacturers recommendations and cracks shall be sufficiently sealed with the crack seal or the seal coat to not allow the penetration of water.

3. Question: "According to the bid notice, joint sealing is not included in the scope of work. Consequently, we will not include joint sealing in our bid. Please correct me if I am wrong."

Answer: The intent of crack sealant was to include all cracks, joints or any other openings allowing water to penetrate. Bidder shall provide joint sealing.

4. Question: "If we had the good fortune to be awarded the work, we would complete the job in the spring/summer of 2020. As you may already be aware, the temperature needs to be 50 degrees and rising to apply the PMM seal coat. The temperature cannot fall below 50 degrees within twenty-four (24) hours of applying the seal coat."

Answer: Bidder shall follow the manufacturer's directions for the install. The County will work with the awarded bidder to schedule work when the temperatures allow installation and around events that are scheduled at the Events Center/Fairgrounds.

Curry County  
ITB #2019/20-06  
Events Center Parking Lot  
Page #3

All of the remaining terms and conditions of Bid No. 2019/20-06 have not been altered or changed and remain the same.

Questions concerning this addendum should be directed to Troy Hall, Purchasing Agent at [thall@currycounty.org](mailto:thall@currycounty.org)

**End of Addendum #1**